

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

NO. 1740/BGM-310/2025-26

Date 28/07/2025

It is Certified that an inspection team headed by Dr. Ramesh Dandagi (Name of Officers with designation) from THO Belagavi (Name of Department/office) inspected the Shri Siddharameshwar English medium school on 28/07/25 (Date and inspection) and found that the _____ (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 30/06/2026

27-07-2026

Signature with seal:

Name: Dr. RAMESH DANDAGIDesignation: THO BELAGAVIName & Address of Health Officer Department:
Belagavi

To
The Principal
Shri Siddharameshwar English Medium School
Shivbasav Nagar, Belagavi



MANAGER
SHRI SIDDHARAMESHWAR
ENGLISH MEDIUM SCHOOL
BELGAUM-10

ATTESTATION




SD/- PRINCIPAL
Shri Siddharameshwar
English Medium School
Shiva Basav Nagar, BELAGAVI-10

ATTESTATION

An ISO 9001:2015 and ISO 45001:2018 Certified Laboratory

Regional Office : Belagavi-1
Karnataka State Pollution Control Board
#1, Main Road, Auto Nagar,
Kambargi Industrial Area, Belagavi-590 015
Telefax : 0831-2459121

ಪ್ರಾದೇಶಿಕ ಕಛೇರಿ : ಬೆಲಗಾವಿ-೧
೧ ನೇ ಮುಖ್ಯ ರಸ್ತೆ, ಆಟೋ ನಗರ,
ಕಾಂಬರ್ಗಿ ಕೈಗಾರಿಕಾ ಪ್ರದೇಶ,
ಬೆಲಗಾವಿ-೫೯೦೦೧೫
ತೆಲೆಫಾಕ್ಸ್:೦೮೩೧-೨೪೫೯೧೨೧



towards a cleaner Karnataka

ANALYSIS REPORT : WATER Regional Laboratory, Belagavi.

NO: PCB/BGMV-1/LAB/AR/2025-26/ 145 Date: 27/5/2025
NAME OF THE STATION : Shri Siddarameshwar English Medium School,
Shivabasavanagar, Belagavi.
SAMPLE COLLECTED BY : HM SSEM' School, Belagavi.
DATE OF COLLECTION : 23-05-2025.
RECEIVED DATE : 23-05-2025.
TIME OF SAMPLE RECEIPT : 11.10 am.
PARTICULARS OF SAMPLE : 144-Water sample collected at School Premises.

| Sl No. | PARAMETERS | UNITS | IS 10500:2012 (Reaffirmed 2018) *AL **PL | | 144 | Test Method |
|--------|-----------------------------|----------|--|------|-------|-------------------|
| 1 | pH @25°C | | 6.5-8.5 | NR | 7.6 | IS:3025 (Part 11) |
| 2 | Dissolved Solids | mg/l | 500 | 2000 | 80 | IS:3025 (Part 16) |
| 3 | Conductivity @25°C | uMhos/cm | - | - | 144 | IS:3025 (Part 14) |
| 4 | Chlorid as Cl | mg/l | 250 | 1000 | 24 | IS:3025 (Part 32) |
| 5 | Sulphate as SO ₄ | mg/l | 200 | 400 | BDL | IS:3025 (Part 24) |
| 6 | Hardness | mg/l | 200 | 600 | 56 | IS:3025 (Part 21) |
| 7 | Calcium as Ca | mg/l | 75 | 200 | 11 | IS:3025 (Part 40) |
| 8 | Magnesium as Mg | mg/l | 30 | 100 | 7 | IS:3025 (Part 46) |
| 9 | Nitrate as NO ₃ | mg/l | 45 | NR | 1.86 | IS:3025 (Part 34) |
| 10 | Iron as Fe | mg/l | 1 | NR | BDL | IS:3025 (Part 53) |
| 11 | Fluoride as F | mg/l | 1 | 1.5 | 0.019 | IS:3025 (Part 60) |

Contd..

| | | | | | | |
|----|----------------------|------|------|-----|-----|--|
| 12 | Total Chromium as Cr | mg/l | 0.05 | NR | BDL | IS:3025 (Part 52) |
| 13 | Alkalinity | mg/l | 200 | 600 | 44 | IS:3025 (Part 23) |
| 14 | Turbidity | ntu | 1 | 5 | 0.2 | IS:3025 (Part 10) |
| 15 | Ammonia as N | mg/l | 0.5 | 0.5 | BDL | IS:3025 (Part 34) |
| 16 | Boron as B | mg/l | 0.5 | 2.4 | BDL | APHA 23 rd edition (Part 4500-B) |

| | |
|------------|---|
| Inference: | Conforms /Non Conforms to AL and PL of IS 10500:2012 Standard with respect to above tested parameters. |
|------------|---|

Note 1. The above results pertain only to the sample tested. 2. AL:Acceptable Limits, P: Permissible Limit (in the absence of alternate Source). 3. The report shall not be reproduced without the written approval of the Laboratory. 4. Sample will be stored for a period of 10 days from the date of dispatch of report. 5. BDL: Below Detection Level in mg/l. 4. Standards are compared with IS 10500 Drinking Water Standards 5. The above results pertain only to the sample. 6. The method of analysis is as per the Standard Method for the examination of Water and Waste water, APHA, AWWA, WPCF, USA and Indian Standards Publication. 7. NR= Not Relaxable.

Analysed By

Abinethri R

SD/- PRINCIPAL
Shri Siddharameshwar
English Medium School
Shiva Basav Nagar, BELAGAVI-10

A TESTATION

Laboratory Head
Authorised Signatory

Scientific Officer
Regional Laboratory
Karnataka State Pollution Control Board
Belgaum.

AB

MANAGER
SHRI SIDDHARAMESHWAR
ENGLISH MEDIUM SCHOOL
BELGAUM-10

ATTESTATION